



## **NATIONAL CERTIFIED TESTING LABORATORIES**

8350 PARKLINE BLVD SUITE 320 • ORLANDO, FLORIDA 32809 • TELEPHONE (407) 240-1356  
FAX (407) 240-8882  
www.nctlinc.com

### **ASTM E1996 COMPLIANCE STATEMENT**

*On December 21, 2005, Clever Covers, Inc. completed impact testing at National Certified Testing Laboratories in Orlando, FL. All tests were performed in full accordance with ASTM E 1886 and ASTM E 1996 .*

*Manufacturer: Clever Covers, Inc. dba Storm Stoppers™  
Product Series: Original 3/8" Translucent Storm Stoppers™ Panel  
Product Configuration Tested: Fixed Panel  
Tested Size: 65" x 108" overall  
Glazing Configuration: N/A*

*Level of Protection: Basic Protection  
Wind Zone: Wind Zone 2 – 120 mph ≤ basic wind speed < 130 mph  
at greater than one mile from the coastline measured  
from the mean high water mark.  
Assembly Height Above Ground: Less than or equal to 30 feet*

*Impact Missile Used: Missile C  
Positive Design Pressure: N/A  
Negative Design Pressure: N/A*

*See NCTL Report 210-3128-1 for complete specimen description and test results.*

### **NATIONAL CERTIFIED TESTING LABORATORIES**

  
Rick Moffett  
Technician

  
Chris Bennett  
Division Manager

  
01/27/06